

# TOWN OF WAYLAND

41 COCHITUATE ROAD  
WAYLAND, MASSACHUSETTS 01778

Julia Junghanns, R.S., C.H.O.  
Director of Public Health  
508- 358-3617  
Fax 508-358-3619  
www.wayland.ma.us/boh

## FLOOR DRAIN REGULATION WAYLAND BOARD OF HEALTH

Effective February 25, 2013

### Section I. PURPOSE OF REGULATION

Whereas:

- floor drains in industrial and commercial facilities are often tied to a system leading to a leaching structure (e.g. dry well, cesspool, leach field) or a septic system; and
- poor management practices and accidental and/or intentional discharges may lead petroleum and other toxic or hazardous materials into these drainage systems in facilities managing these products; and
- improper maintenance or inappropriate use of these systems may allow the passage of contaminants or pollutants entering the drain to discharge from the leaching structure or septic system to the ground; and
- discharges of hazardous wastes and other pollutants to floor drains leading to leaching structures and septic systems have repeatedly threatened surface and ground water quality throughout Massachusetts; and
- surface and ground water resources in the Town of Wayland contribute to drinking water supplies; and
- ground water provides the sole source of the Town of Wayland's drinking water

The Town of Wayland adopts the following regulation, under its authority as specified in Section II, as a preventative measure for the purposes of preserving and protecting the Town of Wayland's drinking water resources from discharges of pollutants to the ground via floor drains, reducing the risk to public health and the environment due to such discharges, and minimizing the threat of economic losses to the Town.

### Section II. SCOPE OF AUTHORITY

The Board of Health adopts the following regulation pursuant to authorization granted by Massachusetts General Laws (M.G.L.) Chapter 111 Section 31 and Section 122. The regulation shall apply, as specified herein, to all applicable facilities, existing and new, within the Town of Wayland.

RECEIVED  
TOWN OF WAYLAND  
TOWN CLERK  
2013 JUN -4 PM 3:49

### Section III. DEFINITIONS

For the purposes of this regulation, the following words and phrases shall have the following meanings:

Commercial and Industrial Facility: A public or private establishment where the principal use is the supply, sale, and/or manufacture of services, products, or information, including but not limited to: manufacturing, processing, or other industrial operations; service or retail establishments; printing or publishing establishments; research and development facilities; small or large quantity generators of hazardous waste; laboratories; hospitals.

Commercial Fertilizer: Any substance containing one or more recognized plant nutrients which is used for its plant nutrient content and which is designed for use, or claimed to have value in promoting plant growth, except un-manipulated animal and vegetable manures, marl, lime, limestone, wood ashes, and gypsum, and other products exempted by regulation of the commissioner. (Commissioner of Agricultural Resources (MDAR))

Department: The Massachusetts Department of Environmental Protection.

Discharge: The accidental or intentional disposal, deposit, injection, dumping, spilling, leaking, incineration, or placing of toxic or hazardous material or waste upon or into any land or water so that such hazardous waste or any constituent thereof may enter the land or waters of the Commonwealth. Discharge includes, without limitation, leakage of such materials from failed or discarded containers or storage systems and disposal of such materials into any on-site leaching structure or sewage disposal system.

Floor Drain: An intended drainage point on a floor constructed to be otherwise impervious which serves as the point of entry into any subsurface drainage, treatment, disposal, containment, or other plumbing system.

Leaching Structure: Any subsurface structure through which a fluid that is introduced will pass and enter the environment, including, but not limited to, dry wells, leaching catch basins, cesspools, leach fields, and oil/water separators that are not water-tight.

Oil/Water Separator: A device designed and installed so as to separate and retain petroleum based oil or grease, flammable wastes as well as sand and particles from normal wastes while permitting normal sewage or liquid wastes to discharge into the drainage system by gravity. Other common names for such systems include MDC traps, gasoline and sand traps, grit and oil separators, grease traps, and interceptors.

Pesticide: A substance or mixture of substances intended for preventing, destroying, repelling, or mitigating any pest, and any substance or mixture of substances intended for use as a plant regulator, defoliant, or desiccant.

Toxic or Hazardous Material: Any substance or mixture of physical, chemical, or infectious characteristics posing a significant, actual, or potential hazard to water supplies or other hazards to human health if such substance or mixture were discharged to land or waters within the Town of Wayland. Toxic or hazardous materials include, without limitation,

synthetic organic chemicals, petroleum products, heavy metals, radioactive or infectious wastes, acids and alkalis, and all substances defined as Toxic or Hazardous under M.G.L. Chapters 21C and 21E or Massachusetts Hazardous Waste regulations (310 CMR 30.000), and also include such products as solvents, thinners, commercial fertilizers, and pesticides in quantities greater than normal household use.

Use of Toxic or Hazardous Material: The handling, generation, treatment, storage, or management of toxic or hazardous materials.

#### **Section IV. PROHIBITIONS**

With the exception of discharges that have received (or have applied and will receive) a Department issued permit prior to the effective date of this regulation, no floor drain(s) shall be allowed to discharge, with or without pretreatment (such as an oil/water separator), to the ground, a leaching structure, or septic system in any industrial or commercial facility if such floor drain is located in:

- A. an industrial or commercial process area,
- B. a petroleum, toxic, or hazardous materials and/or waste storage area, or
- C. a leased facility without either A or B of this section, but in which the potential for a change of use of the property to a use which does have either A or B is, in the opinion of the Board of Health or its agent, sufficient to warrant the elimination of the ground discharge at the present.

#### **Section V. REQUIREMENTS FOR EXISTING FACILITIES**

A. The owner of a facility in operation prior to the effective date of this regulation with a prohibited floor drain system (as defined under Section IV above) shall:

1. Where possible, disconnect and plug all applicable inlets to and outlets from applicable leaching structures, oil/water separators, and/or septic systems; and
2. Remove all existing sludge in oil/water separators, septic systems, and where accessible, leaching structures. Any sludge determined to be a hazardous waste shall be disposed of in accordance with state hazardous waste regulations, 310 CMR 30.000. Remedial activity involving any excavation and/or soil or groundwater sampling must be performed in accordance with appropriate Department policies; and
3. Alter the floor drain system so that the floor drain shall be either:
  - (a). connected to a holding tank that meets all applicable requirements of Department policies and regulations, with hauling records submitted to the Board of Health at the time of hauling;
  - (b). connected to a municipal sanitary sewer line, if available, with all applicable Department and local permits; or
  - (c). permanently sealed.

Any facility sealing a drain shall be required to submit for approval to the Board of Health a hazardous waste management plan detailing the means of collecting,

storing, and disposing any hazardous waste generated by the facility, including any spill or other discharge of hazardous materials or wastes.

B. Any oil/water separator remaining in use shall be monitored weekly, cleaned not less than every 90 days, and restored to proper conditions after cleaning so as to ensure proper functioning. Records of the hauling of the removed contents of the separator shall be submitted to the Board of Health at the time of hauling.

C. Compliance with all provisions of this regulation must be accomplished in a manner consistent with Massachusetts Plumbing, Building, and Fire code requirements.

D. Upon complying with one of the options listed under Section V.A.3., the owner/operator of the facility shall notify the Department of the closure by filing the Department's UIC Pre-Closure Form BRP WS-06d, which may be obtained by calling the Department (617-292-5770), and sending a copy to the Board of Health.

## **Section VI. EFFECTIVE DATES FOR ALL FACILITIES**

The effective date of this regulation is the date posted on the front page of the regulation, which shall be identical to the date of adoption of the regulation.

### **A. Existing Facilities:**

1. Owners/Operators of a facility affected by this regulation shall comply with all of its provisions within 120 days of the effective date;
2. All applicable discharges to the leaching structures and septic systems shall be discontinued immediately through temporary isolation or sealing of the floor drain.

### **B. New Facilities:**

1. As of the effective date of the regulation, all new construction and/or applicable change of use within the Town of Wayland shall comply with the provisions of this regulation.
2. Certification of conformance with the provisions of this regulation by the Board of Health shall be required prior to issuance of building and occupancy permits.
3. The use of any new oil/water separator shall comply with the same requirements as for existing systems, as specified above in Section V.B.

## **Section VII. PENALTIES**

Failure to comply with provisions of this regulation will result in the levy of fines of not less than \$200.00, but no more than \$1000.00. Each day's failure to comply with the provisions of this regulation shall constitute a separate violation.

## Section VIII. SEVERABILITY

Each provision of this regulation shall be construed as separate to the end that, if any provision, or sentence, clause or phrase thereof, shall be held invalid for any reason, the remainder of that section and all other sections shall continue in full force and effect.


Legal notice dates: February 7, 2013 and February 14, 2013

Date of Public Hearing: February 25, 2013


Date of Adoption: February 25, 2013

Date of publication: April 11, 2013

Wayland Board of Health

  
Thomas Klem, Chair

Arnold Soslow, M.D., Vice Chair

  
Michael Wegerbauer  
Michael Bean, M.D.  
Cynthia Hill