

ADDENDUM NO. 1

TO

CONTRACT DOCUMENTS

**VINYL FLOOR TILE INSTALLATION LOKER SCHOOL
Wayland, MA**

21-1024-IFB

June 15, 2021

NOTICE TO BIDDERS

NOTE: Submission deadline is unchanged, scheduled for Thursday, June 17, 2021 at 2:30 PM

The attention of all bidders submitting proposals for “Vinyl Floor Tile Installation Loker School” is called to the following Addenda to the specifications and plans. The items set forth herein, whether of omission, addition or substitution are to be included in, and form part of the specifications and plans of the above-named project for bids to be received as advertised.

**PLEASE BE SURE TO ACKNOWLEDGE
THIS ADDENDUM ON BID PRICING PAGE**

The following clarifications, modifications, deletions and additions are hereby incorporated into and become part of the Contract Documents.

WRITTEN CHANGES AND CLARIFICATIONS TO SPECIFICATIONS

QUESTIONS AND CLARIFICATIONS

Question 1: Please confirm it is 4" rubber base that will need to be installed in each classroom.

Response: Yes the 4" rubber base (in standard black color) is required to be supplied and installed on all walls and surfaces in the classrooms.

Question 2: Please confirm the use of transition strips in each classroom doorway to match the other classrooms should be added into our bid price.

Response: Each classroom doorway will require a transition strip from the existing corridor tile to the new classroom tile.

END OF ADDENDUM NO. 1