

Contaminant	Current MassDEP MCL	Happy Hollow Wells 3/16/24	New EPA Standard
PFOA	PFAS6 MCL - 20 ug/L  Wayland Results - <2.0 ug/L	<2.0 **	4 ppt
PFOS		<2.0 **	4 ppt
PFNA		<2.0 **	10 ppt / Included in Hazard Index Calculation
PFHxS		<2.0 **	10 ppt / Included in Hazard Index Calculation
PFHpA		<2.0 **	No EPA Standard
PFDA		<2.0 **	No EPA Standard
PFBS	No MA Standard	<2.0 **	Included in Hazard Index Calculation
Gen X Chemicals (HFPO-DA)	No MA Standard	<2.0 **	10 ppt / Included in Hazard Index Calculation

\*\* After PFAS Treatment

Contaminant	Current MassDEP MCL	Chamberlain Well 3/16/24	New EPA Standard
PFOA	PFAS6 MCL - 20 ug/L  Wayland Results - 15.9 ug/L	8.42	4 ppt
PFOS		3.84	4 ppt
PFNA		<2.0	10 ppt / Included in Hazard Index Calculation
PFHxS		1.06	10 ppt / Included in Hazard Index Calculation
PFHpA		3.68	No EPA Standard
PFDA		<2.0	No EPA Standard
PFBS	No MA Standard	1.61	Included in Hazard Index Calculation
Gen X Chemicals (HFPO-DA)	No MA Standard	<2.0	10 ppt / Included in Hazard Index Calculation

Contaminant	Current MassDEP MCL	Baldwin Pond 1/14/24	New EPA Standard
PFOA	PFAS6 MCL - 20 ug/L  Wayland Results - 3.42 ug/L	3.42	4 ppt
PFOS		1.38	4 ppt
PFNA		<2.0	10 ppt / Included in Hazard Index Calculation
PFHxS		0.666	10 ppt / Included in Hazard Index Calculation
PFHpA		1.67	No EPA Standard
PFDA		<2.0	No EPA Standard
PFBS	No MA Standard	1.66	Included in Hazard Index Calculation
Gen X Chemicals (HFPO-DA)	No MA Standard	<2.0	10 ppt / Included in Hazard Index Calculation

Contaminant	Current MassDEP MCL	Campbell Well 1/14/24	New EPA Standard
PFOA	PFAS6 MCL - 20 ug/L  Wayland Results - 2.23 ug/L	2.23	4 ppt
PFOS		<2.0	4 ppt
PFNA		<2.0	10 ppt / Included in Hazard Index Calculation
PFHxS		<2.0	10 ppt / Included in Hazard Index Calculation
PFHpA		<2.0	No EPA Standard
PFDA		<2.0	No EPA Standard
PFBS	No MA Standard	1.63	Included in Hazard Index Calculation
Gen X Chemicals (HFPO-DA)	No MA Standard	<2.0	10 ppt / Included in Hazard Index Calculation